



An tÚdarás Slándála Príobháidí
The Private Security Authority

AUDITING GUIDELINES

**Installer of Security Equipment
(Access Control)**

**For Contractors providing
Powered Gates services
(PSA 80:2025)**

www.psa-gov.ie

September 2025

Contents

<u>1.</u>	<u>Scope</u>	3
<u>2.</u>	<u>General</u>	4
<u>3.</u>	<u>System Design–Requirements for Safety</u>	8
<u>4.</u>	<u>System Design–Compliance & Residual Risk Assessment</u>	29
<u>5.</u>	<u>Commissioning</u>	33
<u>6.</u>	<u>Legal Compliance</u>	34

ANNEX A – Gate Compliance & Residual Risk Assesment	43
ANNEX B - Explanations of Essential Health Safety	47
ANNEX C - Certificate of Compliance	50
ANNEX D - Declaration of Conformity & CE Mark	52
ANNEX E - Unsafe System Notice	53
ANNEX F - System Safety Unknown Notice	54
ANNEX G - Factory Production Control (FPC) Checklist	55

1. Scope

This standard provides a specification for compliance with licensing by the Private Security Authority and applies to organisations seeking licences to provide security services as an Installer of Security Equipment (Access Control) who are providing powered gates services. Organisations seeking an Installer of Security Equipment (Access Control) licence will also be required to comply with PSA 74:2019 – Licensing Requirements for Security Service Providers.

The Government of Ireland through the Private Security Services Act, 2004 as amended, established the Private Security Authority (PSA) as the national regulatory and licensing body for the private security industry. Amongst the functions of the PSA are:

- The controlling and supervising of persons providing security services and maintaining and improving standards in the provision of those services.
- Specifying standards to be observed in the provision of security services.
- Specifying qualifications or requirements for the granting of licences.

Organisations licensed by the PSA and those seeking a licence from the PSA must comply with this standard. Certification for licensing purposes will be undertaken by auditors appointed by the PSA. Organisations will be required to pay for the cost of certification audits. Organisations will be notified of the cost of audits in advance.

By applying for and holding a licence, organisations agree to the sharing of information relating to this document, the contents herein and any audit (including audit reports) undertaken for the purposes of PSA licensing between the PSA and the auditor. Where an organisation fails to comply with the requirements of this standard, the auditor is obliged to notify the PSA.

This document is for the purpose of licensing by the PSA and should not be interpreted as meeting any other statutory obligations of an organisation. It is not a technical reference.

Only the most recent edition of the Requirements Document specified by the PSA shall apply for licensing purposes. To ascertain the edition applicable visit the PSA website, www.psa-gov.ie.

2. General

2.1 PSA Licensing Requirements

The PSA requirements document “*PSA Licensing Requirements – Installer of Security Equipment (Powered Gates)*”, hereinafter referred to as PSA 80:2025, sets out the requirements to be achieved and maintained by contractors applying for a licence from the PSA in the Installer of Security Equipment (Access Control) sector.

Contractors seeking a licence from the PSA must comply with PSA 80:2025 & PSA74:2019. A contractor’s compliance shall be assessed against the requirements document by auditors in accordance with these guidelines.

2.2 Approved Auditing Body

2.2.1 Certification for licensing purposes will only be accepted from auditing bodies approved by the PSA to provide auditing services for PSA 80:2025 & PSA74:2019.

2.2.2 Auditing bodies shall agree in writing to be bound by these auditing guidelines and such other requirements as the PSA may require before the PSA will accept evidence of certification from them.

2.3 Audits

2.3.1 Contractors shall be subject to an audit at least once during each calendar year or at such intervals as the PSA may prescribe. The purpose of the audit is to verify compliance with PSA 80:2025 & PSA74:2019.

2.3.2 The PSA may request auditing bodies to focus their audit on certain areas of an organisation’s activities. Such request will be within the terms of PSA80:2025.

2.3.3 All audits shall involve a visit to the contractor’s address as stated on their PSA licence.

Where the address visited is not as stated on the licence, the auditor shall confirm that the address on the licence is the registered address of the organisation. If it is not the registered address, this should be recorded in the audit report. In such instances the address visited should be the administrative office of the organisation.

Where the address on the licence is outside of Ireland, a visit to the contractor’s administrative office in Ireland shall occur. Where the overseas office has access to Irish client files the organisation must provide a statement confirming that the requirements of PSA 80:2025 & PSA74:2019 are being met.

Where the administrative address is outside of Ireland, a visit to the address outside of Ireland shall take place.

Where an organisation has more than one administrative office, all records required for audit purposes should be made available at a single location on the date(s) of the audit. If this is not possible, audits should rotate between the different administrative offices of the organisation.

- 2.3.4** Organisations that change their legal status shall be subject to an audit. A change in legal status includes changing from a sole trader to a company, sole trader to partnership, partnership to company or unlimited company to limited company.

Where a merger of two businesses takes place and a new entity formed an audit is required.

An audit is not required where:

- a. one organisation takes over another organisation, both organisations are PSA licensed and there is no change in the legal status of the first organisation.
- b. where a change in legal status occurs and all partners, directors and shareholders of the new entity were vetted by the PSA as part of the previous entity or entities.
- c. where a sole trader changes to a company and the former sole trader is the exclusive director of the new company.

- 2.3.5** Organisations that change address shall be subject to a visit at their new address before their certification can be amended.

- 2.3.6** Audits shall be conducted in accordance with these guidelines. Where the guidelines require the recording of an action or other matter this shall be recorded in the audit report.

- 2.3.7** Where PSA 80:2025 or these guidelines require an auditor to inspect or sample records or other documents the auditor shall select at random from a list of such records or documents the ones to be audited. Under no circumstances shall an auditor accept records chosen or selected by the organisation.

In selecting records or documents, auditors shall select a large enough sample as to be satisfied that a representative selection has been chosen. Inspectors shall, where possible, select different samples at subsequent audits.

As a minimum, the size of a sample shall equal the square root of the total records. Where the sample size exceeds 25 the auditor may stop at 25 if satisfied that a pattern of compliance has been established from the selected sample.

The name of each sample record/document should be recorded.

- 2.3.8** When an organisation has successfully completed an audit they shall be issued with a certificate of compliance or letter of approval certifying same. Certificates or letters of approval shall be issued for a maximum period of 2 years.

At the same time, the auditor shall email the PSA a copy of each new certificate/approval letter (in PDF format).

2.3.9 When an audit has been completed the auditor shall notify the PSA of same and provide a copy of the audit report on request.

Note: Provision of a copy of the certificate of compliance/registration in accordance with clause 2.2.8 shall be accepted as notification.

2.3.10 Audit reports shall be in a format agreed with the PSA.

2.3.11 Where a contractor fails to obtain full compliance to PSA 80:2025 or fails to arrange an audit for same, the auditor shall notify the PSA.

2.4 Audit Compliance

2.4.1 Full compliance with PSA 80:2025 & PSA74:2019 in accordance with 2.5 must be achieved before certification can be issued.

2.4.2 Where an organisation fails to comply with any of the requirements of the requirements document, details of all the non-compliances shall be recorded in the audit report together with details of the required corrective actions and the timeframe by which the corrective action is to be completed.

2.4.3 When corrective action has been completed, this should be recorded on the audit report together with details of how the corrective action was verified by the inspector, e.g. email, re-visit, etc.

2.4.4 When finalised audit reports should detail all non-compliances and corrective actions.

2.5 Audit Non-Conformances

2.5.1 Where a contractor fails to meet any of the requirements of PSA 80:2025 this shall be recorded as a non-compliance in accordance with the categories specified in these auditing guidelines. Organisations have 5 weeks from date of audit to rectify a non-conformance.

The following criteria shall apply to non-conformances.

a. Organisations shall not pass an audit where:

- A category 1 non-conformance is present, or
- 3 or more category 2 non-conformances are present, or
- 6 or more category 3 non-conformances are present, or
- A combination of 6 or more category 2 and category 3 non- conformances are present.

All non-conformances at 1) must be closed before an audit is passed.

b. An organisation may pass an audit where:

- Less than 3 category 2 non-conformances are present, or
- Less than 6 category 3 non-conformances are present, or
- A combination, where a) is not broken, of less than 6 category2 and category 3 non-conformances are present.

Organisations are still required to rectify all non-conformances. However, any follow up action by the auditor may be deferred until the next audit. If at the next audit a non-conformance has not been rectified the non-conformance category shall move up a level.

- c. Section 1 of the above criteria continues to apply where an organisation rectifies some of their non-conformances. An organisation may not move from section 1 to section 2 by virtue of rectifying a non-conformance.

2.5.2 Where the 5 week period referred to in 2.6.1 has elapsed and an organisation has not passed an audit, the auditing body shall write to the organisation.

The organisation shall be required to rectify all outstanding matters within 14 days. They shall be advised that failure to rectify to do so within 7 days of the expiration of the 14 day timeframe, will result in their certification being withdrawn and the PSA notified of same.

2.5.3 On receipt of notification that an organisation's certification has been withdrawn the PSA will commence compliance action against the organisation. This action may result in the suspension or revocation of an organisation's licence.

2.5 Audit Reports

2.5.1 An audit report shall be produced for each audit completed. The audit report shall include the following information:

- The name of the auditor(s) who undertook the audit,
- The date(s) of the audit(s),
- The name, address, contact details and PSA licence number of the contractor,
- A summary of the audit highlighting any non-conformities found.
- Update report on screening and training records reviewed to date (see Annex A).

2.5.2 A copy of the audit report shall be sent by the auditor to the PSA upon request. The report should be submitted with 7 days of receipt of such a request.

2.6 Certification

2.6.1 All certificates/letters of approval for PSA 80:2025 issued by the auditor shall contain the organisation's address as recorded on the organisation's PSA licence.

3. System Design – Requirements for safety

3.1 Design and suitability of the system

The system shall be designed and specified to reflect the demands of the site and the needs of users. Factors that shall be considered are:

- Environment (wind, rain, flood risk, dust, ultra violet, flora and fauna)
- Location (sloping ground, emergency entry and egress, visibility and nature of traffic)
- Duty cycle (how often the system will operate per hour/24-hour period)
- User vulnerability (vicinity to the public, young children, people with physical and sensory limitations and people with learning restrictions)

The final specification shall be compliant with this requirements document, be drawn up as a design proposal and be agreed with the client.

The auditor shall inspect the system design proposal is as specified and reflects accurately the demands of the site and the needs of the users and meets the requirements of clause 3.1.

Non Compliance: Category 1

3.2 Compliance & Residual Risk Assessment

A compliance & residual risk assessment shall be conducted for the design of a new system, for the installation of a complete system supplied by a 3rd party, or upon modification of an existing system and prior to taking on any reactive or planned maintenance of a system for the first time. The assessment shall include the seven steps described in section 5.

Where the assessment of a new system supplied with a Declaration of Conformity and a CE mark by a 3rd party indicates that the system may not achieve the state of the art, the installation contractor shall refer to Annex H.

Where the risk assessment of such a system indicates that the state of the art is achieved but residual hazards are present based on its local environment or use, the installation contractor shall address them.

The auditor shall confirm and inspect that a Compliance & Residual Risk Assessment has been carried out for the design of a new system, for the installation of a complete system supplied by a 3rd party, or upon modification of an existing system and prior to taking on any reactive or planned maintenance of a system for the first time.

Non Compliance: Category 1

3.3 Certificate of Compliance

Contractors shall issue a certificate of compliance to clients upon:

- taking on the maintenance of an existing compliant system
- the completion of a safety upgrade to an existing system
- the completion of minor modification of an existing system

Alternatively, where the compliance assessment of an existing system indicates non-compliance with this requirements document, an unsafe system notice shall be issued instead. Where access to safety critical elements cannot be achieved safely, a system safety unknown notice shall be issued instead.

The auditor shall confirm by inspecting sample records to verify that Certificates of Compliance have issued to all clients in line with Clause 3.3.

Non Compliance: Category 1

3.4 Hazard types and Control Measures Required for Compliance

Hazard	Description	Control measures for compliance
Structural failure	Where structural faults cause falling down or derailment	3.5
Electrical	Electric shock, fire, loss of control or safety	3.6
Crush	Reducing gap less than 500mm in horizontal movement, or any vertically reducing gap	3.7, 3.8, 3.9, 3.10, 3.11
Impact	Contact with a moving leaf in the swept area, outside of any crush zone	3.7, 3.9, 3.10, 3.11
Shear	The guillotine effect where elements pass	3.7, 3.8, 3.9, 3.10.2, 3.11
Draw-in	Where body parts may be dragged into a gap	3.7, 3.8, 3.9, 3.10.2, 3.11
Imprisonment	Where escape from an enclosed area is prevented by fault or power cut	Alternative route or 3.7, 3.13
Hooking/cutting	Sharp edges or snagging of clothing	Alternative route or 3.7

Installations shall be designed to eliminate hazards wherever reasonably practicable rather than use sensitive devices to control hazards created by the design. All hazards related to moving parts shall be controlled or eliminated up to a height of 2.5m above ground level, or any other permanent access level e.g. stairway or mezzanine floor. The requirements for safety in this section relate equally to new or existing systems.

The auditor shall confirm that all Hazard Types have been identified and controlled as required in Clause 3.4.

Non Compliance: Category 1

3.5 Structural Integrity

It shall be demonstrated that a gate or barrier leaf and its supporting structures are designed to resist permanent deformity, ultimate structural failure and derailment in normal use, manual use or under foreseeable misuse. Any deformity that does occur in use shall not be detrimental to safety or function.

A gate or barrier leaf, its supporting structure and any suspension elements shall be designed such that falling down, collapsing or derailment is prevented in normal use and under foreseeable misuse conditions as follows:

- a) Gate or barrier leaves, their supporting structures, suspension elements and fixings shall be designed to withstand 2 x the total foreseeable load without permanent deformity.
- b) Gate or barrier leaves, their supporting structures, suspension elements, fixings and any travel stops, shall be designed to withstand 3.5 x their total foreseeable load without ultimate structural failure.
- c) Swing and folding gate systems shall be protected against hinge failure whereby if a hinge fails the gate will not drop nor move more than 300mm off its vertical axis. They shall also be protected against being lifted more than 50% of their hinge pin length.

In particular, travel stops shall prevent derailment (e.g. sliding gate) and suspension element failure (e.g. hinge failure) when used in manual and in windy conditions. Foreseeable misuse shall be allowed for, which could mean a user moving the gate too fast in manual. It shall be possible to secure the gate against wind action in the fully open and closed position, particularly when used in manual mode.

The effects of wind shall be taken into account in the structural assessment. The system shall remain safe when subject to foreseeable wind loadings. A system is not necessarily required to remain functional in high winds (although client/contractual requirements might require otherwise); the system shall, however, remain safe.

Information on predicting wind pressures on buildings can be found in EN 1991-1-4. This is not an exact science, hence considerable margin for error shall be applied where there is doubt.

The auditor shall confirm that all supporting structures have been reasonably assessed as required in Clause 3.5.

Non Compliance: Category 1

3.6 Electrical Safety

3.6.1 Supply Wiring

The supply to the installation shall be provided, tested and certified to comply with IS 10101 as currently amended. Where an existing supply is utilised, evidence shall be gained to demonstrate that it has been tested to ensure safety and compliance with IS 10101 (e.g. client Electrical Installation Certificate or Periodic Inspection Report copy).

3.6.2 System Wiring

The electrical and control system beyond the supply terminals shall be built and tested using the same basic principles described in IS 10101 and EN 60204-1. It shall be proven by either measurement or calculation that the total earth fault loop impedance of the entire installation is within the specification of the circuit protective device.

3.6.3 Isolation

A means to safely electrically isolate the system for maintenance shall be provided. Where an electrical isolator is remote from the system, i.e. cannot be seen from the place of work, it shall be prevented from being turned on during maintenance and warning notices posted.

3.6.4 Conductive Parts Earthing

Where class 1 earthed equipment (230/400v earthed) is present, all extraneous conductive parts shall be connected to the supply earth terminal or prove to have a resistance of less than 0.5 ohm to the earth terminal. *Please note that many 24v electric operators are in fact 230v class 1 devices*

3.6.5 Differing Voltage Bands

Where cables containing differing voltages share a conduit, all cables shall have a voltage rating of the highest voltage present or the higher voltage cable shall be surrounded by an earthed metallic screen, for example, steel wired armoured (SWA) cable or similar.

3.6.6 Communication or Data Cables

Where communication or data cables share a conduit with power cables, clause 3.6.5 above shall apply with the addition that the data cable shall also be screened and earthed.

3.6.7 Cable Ratings

Cables shall be rated for the voltage present and the maximum current possible; volts drop shall be no more than 5% or within the control system supplier's specification.

3.6.8 Flexible Cables

Cables used to connect equipment that moves relative to fixed elements in normal use (e.g. rams) shall be of multi- stranded conductors to IEC 60228 class 5 or 6 (multiple fine strand copper conductor, not SWA, etc.).

3.6.9 Electrical Enclosures

- Enclosures subject to external conditions shall be at least IP54
- Enclosures and drive units used below ground shall be at least IP67
- Enclosures containing dangerous voltages shall be marked with an appropriate dangerous voltage label and be openable only by means of key or tool

3.6.10 Mechanical Protection of cables

All vulnerable cabling shall be provided with mechanical protection by means of conduits, trunking or armouring. Vulnerable cabling is anything containing 230v or greater or anything that forms part of a control system; examples include photo beam cables, safe edge cables, light grid/laser scanner etc. cables, motor cables, encoder cables or access control device cables. All cables, trunking, conduits and enclosures shall have adequate UV protection where they are subject to sunlight.

3.6.11 Control System Integrity

Where a third party has provided the control system, the control panel/motor manufacturer's Declaration of Incorporation shall be present, and the relevant instruction manual followed.

Alternatively, if the manufacturer or assembler has built their own control system they shall type test the system for conformity with Machinery Directive EH&SR 1.2 (Safety and Reliability of Control Systems), all other relevant EH&SRs, and all applicable product safety directives (see section 7). This will include the Electromagnetic Compatibility Directive (electrical devices) and the Radio Equipment Directive (radio devices) where applicable. Test reports shall be available to prove compliance when required.

Activation of a safety device at one hazard location shall not lead to any further hazards at other locations on the system. In the event of a fault in the safety system it shall prevent further movement by at least the end of the current open/close cycle.

3.6.12 Safety Device Circuits

The system connecting safe edge, light grid or laser scanner etc. devices shall be fully compatible with the control system they are connected to such that, as installed, they conform to category 2 or 3 of EN 954-1 or EN ISO 13849-1.

The circuit shall be either protected from short circuit faults by a control panel derived category 2 test of the circuit at least once in every cycle, or for some category 3 devices not protected from short circuit faults, by means of:

- minimum 1mm² csa conductors, and
- use of short as possible cable routing, and
- use of crimped, ferruled or tinned conductor ends to prevent stray strands, and

wherever reasonably practicable, the device shall be placed within the control panel, or failing that be connected via armoured cable or cable in conduit

3.6.13 Post 2018 System

Systems produced after 2018 (since the publication of EN 12453:2017+A1:2021) are required to have all safety related parts of the control system in conformity with EN 13849-1 at minimum performance level C through the entire control system from any switch or sensing element to the motor terminals or be in full conformity with EN 60335-1 and 2; this shall include any wicket gate stop switch. The following devices will additionally need to achieve at least category 2 as installed and prevent further movement by at least the end of the current open/close cycle in the event of a fault:

- non-contact presence detection device
- pressure sensitive device (safe edge)
- limit switch

3.6.14 Wicket Gate

Where a wicket gate is fitted in an automated gate, movement of the main gate shall be stopped whenever the wicket gate is not in a safe position; devices and wiring used to achieve this shall only fail to a safe condition.

The auditor shall obtain a declaration signed and dated by a principal of the organisation that all installations, repairs and servicing has been conducted in accordance with all electrical safety requirements in Clause 3.6.

Non Compliance: Category 1

3.7 Safety distances

Guards or fencing can be used to prevent access to hazardous movement and shall:


- be permanently fixed and only removable with a tool or key, and
- be durable and resistant to foreseeable abuse, and
- be designed to resist climbing with vertical elements on the outside and a maximum gap of 40mm between verticals and, conform with tables 1 and 2 for reach over and reach through protection

Height of guard	Height of leaf		
	2	2.2	2.4
	Horizontal clearance		
2	350	350	100
2.2	0	250	100
2.4	0	0	100
2.5	0	0	0

Table 1 – data from EN 13857

Rectangular aperture smallest dimension	Horizontal clearance
18.5 or less	120
18.6 to 29	300
29.1 to 44	500
44.1 to 100	850

Table 2 –from Annex B of EN12453:2017+A1:2021




Various safety distances exist (derived from EN 349 & EN 12453:2017+A1:2021) to prevent injury to differing body parts:


Crush hazard		Draw-in/shear hazard
Finger = 25mm Hand wrist = 100mm Arm, foot = 120mm	Leg = 180mm Head = 300mm Body = 500mm	Finger = 8mm (4mm at a hinge)

These can only be applied or utilised at points where only that size of body part could reasonably be affected. Hence use of these distances, other than 500mm, is severely restricted in most cases. For example, there is no point restricting a reducing gap to 25mm where an arm or leg could easily be inserted; the arm or leg would be seriously injured when the gap reduces to 25mm.


A gap greater than 500mm between a horizontally moving leaf and a fixed object eliminates the crush hazard potential at that location.



Swing door/gate



Relaxation to 200mm




Sliding door/gate

within 250mm of the hinge

However, an impact hazard will remain across the swept area of the leaf during movement that shall be controlled by one or more of the means described in 3.8 & 3.9

A foot crush hazard can be prevented by ensuring the gap under the leaf in the swept area is:

- 1) less than 8mm or more than 120mm, and
- 2) constant, without of slopes and kerbs, etc.




Less than 8mm and level	More than 8 and less than 120 or not level	More than 120 and level =
= impact	= crush & impact	impact


Hazards in the swept area shall be controlled by one or more of the permitted control measures: hold-to-run, force limitation or non-contact presence detection. Where force limitation is used, the nature of the hazards in the swept area will dictate the maximum force that can be used:

- 3) crush & impact hazards in the swept area = 400N maximum
- 4) impact only in the swept area (no crush) = 1400N maximum

A safe edge used to protect a sliding gate draw-in hazard shall be positioned as close as possible to the moving leaf to prevent draw-in occurring.




a) = Infill gaps >120mm b) = infill gaps <120mm c) = fine mesh or solid




The minimum distance allowable between the moving leaf and safe edge shall be verified with a rigid rectangular test piece measuring 120mm x 120mm x 500mm. The test piece shall be placed as deep as possible into the leaf infill material; the safe edge shall be in close enough proximity to be activated by the test piece when the leaf is moved in manual. The nature of the gaps in the leaf infill dictate safe positioning of the safe edges.

Reducing gaps at the hinge area can generate very high force. Access to a reducing gap at a hinge

area is possible from a variety of directions (see below). Reducing gaps at the hinge area shall be avoided by safe design wherever possible. A safe design hinge area shall have a gap of less than 100mm, less than 4mm or greater than 25mm, and any gap-change shall be less than 20%.



Access to reducing gaps



Safe design hinge area

Safe design hinge area criteria:

- a constant gap of less than 4mm or more than 25mm, or
- where the overall gap is less than 100mm, a changing gap of 20% or less.

When the safe design hinge area criteria is not met, one or a combination of the following measures shall be applied such that the hazard is controlled:

- Hold to run
- Safe edge
- Flexible guard
- Fine mesh to prevent access through the infill
- Non-contact presence detection

The auditor shall obtain a declaration signed and dated by a principal of the organisation that all installations, repairs and servicing has been conducted in accordance with all safety requirements in Clause 3.7.

Non Compliance: Category 1

3.8 Hold to Run

Sustained pressure on the activation device shall be required to move the leaf and:

1. the leaf shall travel no more than 100mm on release of the activation device, and
2. for sliding gates, the leaf shall travel no more than 50mm on release of the activation device in the last 500mm of horizontal movement, and
3. only trained users shall use the system; hence the activation device shall prevent unauthorised use where untrained persons might be present (by use of key switch or similar), and
4. the device shall be designed or placed such that it can only be used in a position that allows full, direct, and permanent real-time view of the leaf during the leaf movement and ensures that the person controlling the gate or barrier is not in a hazardous position, and
5. only one device shall be active at any one time, and
6. the leaf shall travel at no more than 0.5m/sec (for converging leaves this means 0.25m/sec. each)

Note: According to EN 12453:2017+A1:2021, video cameras do not give a full, direct, and permanent real-time view

Hold to run can be used to control **crush, impact, shear or draw-in** hazards.


The auditor shall view the required number of installations to verify the requirements of clause 3.8 are being met.

Non Compliance: Category 1

3.9 Force Limitation (safe contact solutions)

The maximum allowable forces and durations are:

- 400N at crush, shear and draw-in hazards (all vertically reducing gaps and horizontally reducing gaps of 500mm or less)
- 1400N at horizontal impact hazards (contact with a horizontally moving leaf outside of a crush, shear or draw-in zone)
- The maximum time force can remain above 150N in all cases is 0.75 seconds
- The maximum time force can remain above 25N in all cases is 5 seconds
- The maximum time a force can exist at or below 25N in all cases is infinite



Force limitation maximum values

3.9.1 Safe Edge

Force limitation can be provided by safe edge in resistive, optical, mechanical, or pneumatic format and:

- the safe edge and any control device shall conform to EN 12978
- the safe edge shall provide the permitted force and time figures
- the safe edge shall protect the full height/width of the crush/impact zone with the exception that the edge does not need to be sensitive in the final 30mm of each end
- the control circuit shall meet the requirements of 3.6.12

The required safe edge specification is governed by leaf overtravel (stopping distance). The speed & weight of the moving leaf, the reversal torque of the operator and the time the control system takes to

react all affect overtravel. The available overtravel in the safe edge will need to be greater than the overtravel of the leaf in all but the lightest of systems.

A safe edge can be used to control any **crush, impact, shear or draw-in** hazard.

3.9.2 Inherent Force Limitation

Force limitation at some hazards can be provided by sensitive drive units.

The system shall reliably provide the permitted force and time figures.

Inherent force limitation can be used to control some, but not all hazards:

- Inherent force limitation shall not be used to control draw-in hazards, by implication, this will also apply to any associated shear hazards.
- Inherent force limitation is unlikely to be able to provide safe force at reducing gaps in the vicinity of the hinge on hinged systems, particularly in reducing hinge gaps, or at the lower edges in the hinge area.

These areas will normally need safe edges to provide force limitation. If inherent force limitation is to be relied upon to provide force limitation in these areas, the resulting crush force shall be measured directly in that location.

- Inherent force limitation systems are unlikely to provide safe force on hinged systems when subject to high winds. It will usually be necessary to rely on safe edges for force limitation on such systems, given that the system shall be safe in all conditions. If inherent force limitation is to be relied upon for such a wind affected system, evidence shall be provided that safe force is achieved, even in high winds.

3.9.3 Force Measurements

Testing shall be carried out with an annually calibrated instrument that complies with EN 12445 or EN 12453:2017+A1:2021.

3.9.4 Force Measurement of New Pre-CE Marked Systems

Installation companies commissioning new pre-CE marked systems shall conduct testing in accordance with the installation and commissioning instructions supplied with the gate or barrier.

3.9.5 Force Measurement of all Other Systems

Tests shall be conducted with an annually calibrated instrument that complies with EN 12453:2017+A1:2021 or EN 12445. Manufacturers type testing for serial production will involve many multiples of tests, in accordance with the relevant standard but, when doing one-off testing of individual systems as part of commissioning or maintenance, a reduced number of tests is more appropriate. In general, each test position shall be tested once but, where the result is in excess of 90% of the maximum permitted value, it shall be repeated three times and the average of all three tests taken as the actual result.

The 90% threshold values above which an average of three tests shall be used are:

- 360N (400N maximum) for crush hazards


- 1260N (1400N maximum) for horizontal pure impact hazards
- 0.68 seconds (0.75 second maximum) for force to remain above 150N
- 4.5 seconds (5 second maximum) for force to remain above 25N

3.9.6 Force Measurement Point on Traffic Barriers

The measurement shall be taken with a 2m maximum extension fitted to the tester:

- 200mm in from the tip of the arm, and
- at an angle that results in the face of the tester being parallel with the arm

Lightweight gravity deployed skirts (not fixed or linkaged) may be tied up out of the way for the test. This will mean that any system utilising a safe edge will need the skirt to collapse such that it reveals the safe edge.



The test shall result in a 400N maximum and achieve force reduction in line with 3.10.

Note1(normative): Fixed or linkage connected skirts shall be assessed in terms of reachable hazards in reducing gaps in the skirt during the opening and closing phases and appropriate control measures applied in line with 4.6.

3.9.7 Force Measurement Points on Horizontally Moving Gates

Test 1. An initial measurement shall be taken at the mid height (or for gates taller than 2800mm high at 1500mm above ground) with an extension on the tester that results in testing at full speed movement

Test 2. Then at three heights with a 500mm extension on the test meter:

- 2.1. 300mm from the top of the gate (or for gates taller than 2800mm high at 2500mm above ground)
- 2.2. At the mid height or 1.5m, whichever is the lower
- 2.3. 50mm up from the base of the gate

Test 3. The point of highest reading at points in tests 2.1. 2.2. & 2.3 is then re measured with no extension on the test meter (50mm)


The gate shall be tested in the mode in which it is to be used. If a leaf delay is used, it shall be

tested with that same delay; if no delay is used, the leaves shall be tested as they converge.


Sliding gate test position -




Swing gate test position (with leaf delay) -



Swing gate test position (without leaf delay) -



Folding gate test position -



Single leaf systems shall be tested at the closing post instead of being tested against the other leaf.

The auditor shall obtain a declaration signed and dated by a principal of the organisation that all relevant force measurements and tests have been carried out for all installations as per the requirements of Clause 3.9. The auditor shall sample installs to verify the requirements of Clause 3.9 are being met.

Non Compliance: Category 1

3.10 Result Assessments

3.10.1. Result assessment for hazards not tested directly – sliding

As testing at draw-in points on sliding gates is not usually possible or safe, the full speed main edge result can also be used to assess safe force at other hazards in the swept area.



This method assumes that opening and closing speeds and settings are equal.

Comparing the full speed result, with the protection used on the main edge, and the protection used at other swept area crush, shear and draw-in hazards, reveals what action is necessary as explained in the following table.


Trailing edge open impact hazards can be assessed directly from the main edge test results, other crush, shear and draw-in hazards can be assessed as follows.

Full speed result at the main edge	Main edge protection	Swept area hazard protection	Result assessment outcome and required action at swept area hazards.
Up to 400N	Safe edge	Same	OK – no further testing/action required
Up to 1400N	Safe edge	Larger	<i>Not verified – test sample of the larger safe edge on the main edge</i>
Up to 400N	Safe edge	Smaller	<i>Not OK – fit equal size safe edge</i>
Up to 1400N	Safe edge	Same/smaller	<i>Not OK – fit larger safe edge</i>
Up to 1400N	Inherent	Safe edge	<i>Not verified – test sample safe edge at the main edge</i>
Up to 1400N	Inherent	Inherent	<i>Not OK – inherent force limitation not suitable for draw-in</i>


3.10.2. Result assessment for hazards not tested directly – swing and folding

The full speed main edge result can also be used to assess safe force in the swept area of swing/folding doors & gates as follows:

- 1) **Where the swept area does contain crush hazards, the full speed main edge test shall result in 400N or less, or**
- 2) **Where the swept area does not contain crush hazards, the full speed test at the main edge could result in as much as 1400N.**



Comparing the full speed result with the protection used at the main edge, and the protection used at the hazard being assessed, can reveal what action is necessary. This is explained in the following table.



Full speed result at the main edge	Main edge protection	Swept hazard area protection	Swept area hazard	Result assessment outcome and required action at the swept area hazard
400N or less	Safe edge	Safe edge	Crush	OK – no further testing/action required
401N to 1400N	Safe edge	Safe edge	Impact only	OK – no further testing/action required
400N or less	Safe edge	Inherent or smaller safe edge	Crush	Not verified – safe edge/larger safe edge needed in the area close to the hinge, or measure force at the hazard
401N to 1400N	Safe edge	Inherent or smaller safe edge	Impact only	Not verified – test inherent at the main edge (away from the safe edge)
400N or less	Inherent	Inherent	Crush	Not verified – safe edge needed in the area close to the hinge, or measure force at the hazard
401N to 1400N	Inherent	Inherent	Impact only	OK – no further testing required

3.10.3. Supplementary Device

Force limitation is not considered to be universally safe. Where users are untrained, the means of activation is remote from the system, or there is reasonable possibility that untrained people will be affected, supplementary devices for the detection of people (e.g. photo beams) shall be added. This is to reduce the probability of contact with force limited movement.

The supplementary device shall be active somewhere between 700mm and the ground, and no more than 200mm horizontally from the face of the leaf and active across the entire width.


For hinged doors and gates, where an inner device is used, it shall be active no more than 200mm horizontally from the open extremity of the swept area.

For traffic barriers, either one device active directly below the arm, or two devices, one on either side within 200mm of the arm are permitted.

Table 1 of EN 12453:2017+A1:2021 provides the minimum level of protection necessary at the main edge when using force limitation.

Activation	Users present		
	Only trained users present	Trained users, untrained people present	Untrained users
Impulse activation in sight	No supplementary device needed	No supplementary device needed	Supplementary device required
Impulse activation out of sight	No supplementary device needed	Supplementary device required	Supplementary device required
Automatic	Supplementary device required	Supplementary device required	Supplementary device required

Systems manufactured after 2018 (since publication of EN 12453:2017+A1:2021), with a distance greater than 150mm between the device and the opposite face of sliding and vertically moving leaves, are required to have a device active on both sides.



The auditor shall obtain a declaration signed and dated by a principal of the organisation confirming that they have adhered to the requirements of Clause 3.10. The auditor shall sample installs to verify the requirements of Clause 3.10 are being met.

Non Compliance: Category 1

3.11 Non-contact Presence Detection

Non-contact presence detection systems are those that that can prevent a person from being touched by the moving leaf. When a system is fully protected by non-contact presence detection, there is no need for force limitation, but the system shall be tested for


effectiveness, and the following:

1. The device shall be compliant with EN 12978
2. Any background field auto adjust time shall be at least 30 seconds
3. As installed, the system shall meet the requirements of section 4.6.12

Single beam photoelectric beams are not included, unless they can exclude all possible contact with the hazard, for example, when attached to the lower edge of a vertically moving door or barrier.

There are two permitted methods of providing protection:

1. Acting directly in the movement plane of the door/gate:
 - acting within or through drillings in the guides (e.g. shutters), or
 - a device mounted on and traveling with the main edge (see 'd' below)
2. Acting to create safety zones on both sides of the door/gate, extending a distance 'd' horizontally from the face of the door/gate/barrier:
 - related to the speed and height of the door, but no less than 200mm, and
 - dimensioned to activate before a person can be contacted



Compliance and effectiveness of the system is not verified by configuration or mounting position, but by testing.

Non-contact presence detection technology can be used to control any crush, impact, shear, draw-in or lifting hazard. There are no limits on the presence of untrained persons or means of activation with this type of protection.

NOTE: Be aware that these systems can be subject to nuisance tripping due to adverse environment and weather conditions (heavy rain, snow, wind-blown debris or animals and birds). Where systems can be desensitised to accommodate these effects, they shall still pass the tests set out below and will require re-testing following any adjustments.

This technology can be used to control **crush, impact, shear or draw-in** hazards.

3.11.1 Testing Non-contact Presence Detection.

Installation companies commissioning new pre-CE marked systems shall conduct testing in accordance with the installation and commissioning instructions supplied with the gate or barrier, or use the methods in 3.11.2 to 3.11.5


On site testing as part of commissioning or maintenance, is conducted with rigid material test pieces as follows.

Test Piece A

Rigid material 700mm x 300mm x 200mm.

Painted matt black on three sides RAL 7040 grey on the other three.

Used for impact and whole-body simulation.



Test Piece B.

Rigid material 300mm x 50mm painted, half matt black and half RAL 7040 grey.

Used for arm, hand and foot simulation.



The reaction of the system to an activation of the device will be crucial. In some locations, the resulting reversal can result in un-protected movement at other hazards. For this reason, pause, stop, or even emergency stop may be the required reaction to activation on some systems. No contact with hazardous movement is permitted in a successful test.


NOTE: Machine safety legislation dictates that activation of a safety system at one hazard location shall not create further hazards on other parts of the machine.

3.11.2 Testing Non-contact Presence Detection on a Sliding Gate

Test pieces A & B shall be presented towards the moving leaf at all hazard areas from both sides. Test piece A shall be used at impact hazards and test piece B shall be used at crush, shear and draw-in hazards.

Movement shall cease before the test pieces are impacted, crushed, sheared or drawn-in.


Test piece A is also placed in the dead zone with its 200mm dimension horizontal to the leaf; no movement shall be possible.



Test piece A is oriented with the 700mm dimension vertical

3.11.3 Testing Non-contact Presence Detection on Swing Gates

Test pieces A & B shall be presented towards the moving leaf at all hazard areas from both sides. Test piece A shall be used at impact hazards and test piece B shall be used at crush hazards.




Test piece A is oriented with the 700mm dimension vertical

Hazardous movement shall cease, or the leaf shall reverse, before the test piece is impacted or crushed. If the leaf reverses, the leaf shall remain protected during the reversal movement.

3.11.4 Testing Non-contact Presence Detection on Folding Gates

Test pieces A & B shall be presented towards the moving leaf at all hazard areas from both sides. Test piece A shall be used at impact hazards and test piece B shall be used at crush hazards.



In this example, 4 x laser scanners are protecting the inner surfaces and a single light grid is protecting the outer face. The threshold device will need to activate 'emergency stop' in order to prevent crush or impact within the "V" between the leaves.

If the leaf retracts, the leaf shall remain protected during the reversal movement.


3.11.5 Testing Non-contact Presence Detection on Barriers.

Test pieces A & B shall be presented towards the moving leaf at all hazard areas from both sides. Test piece A shall be used at impact hazards and test piece B shall be used at crush hazards.

Example 1 - Single laser scanner is providing an exclusion zone 'd' either side of the arm.

Test piece A shall be offered to all points at the periphery of the protection zone from both sides with the 700mm dimension vertical.



Contact with hazardous movement shall be prevented.



Example 2 - Two laser scanners or light grids are used to provide a 2.5m high exclusion zone either side of a barrier fitted with a linkage operated (fixed) skirt that has crush hazards in the skirt as the arm raises.

Test piece A shall be offered to all points at the periphery of the protection zone from both sides during closing (700mm dimension vertical). Test piece B shall be offered to reducing gaps associated with the skirt during opening.

Contact with hazardous movement shall be prevented.



The auditor shall obtain a declaration signed and dated by a principal of the organisation that all relevant measures have been carried out for all installations as per the requirements of Clause 3.11. The auditor shall sample records to verify the requirements of Clause 3.11 are being met.

Non Compliance: Category 1

3.12 Imprisonment Hazard Control

An imprisonment hazard is caused when the gate is the only route out of an enclosed area where people can come to harm. In such environments, a manual release shall be provided at the gate. Where untrained users will be affected, user instructions shall also be displayed.

The gate shall remain safe when being used in manual mode and also when power is restored unexpectedly.

NOTE: Depending on the location and use, fire safety regulations may require additional escape means that are less restrictive to use – e.g. push bar swing doors. Very few automated gates could achieve the ease of use required for an emergency escape route in a multi occupancy building. Care shall be taken to ensure that the system will not contravene fire safety legislation. Organisations shall consult Technical Guidance B document for more accurate escape routes.

The auditor shall obtain a declaration signed and dated by a principal of the organisation that the relevant hazards have been considered and all reasonable action has been taken to meet the requirements of Clause 3.12. The auditor shall sample installations to verify the requirements of Clause 3.12 are being met.

Non Compliance: Category 1

3.13 Manual Use (automated system in manual mode)

Use of the manual opening and closing systems shall not introduce hazards. Moving the leaf in manual shall be achievable with ease and, where more than one person is required to move the leaf in manual mode, the customer shall be made aware of this and the user instructions shall also explain this.

A safe force for one person to move a leaf in manual is 390N in industrial environments.

The auditor shall examine that manual opening and closing systems are meeting the requirements of Clause 3.13 as specified.

Non Compliance: Category 1

3.14 Residual Risk Assessment

A residual risk is the risk that remains after the state-of-the-art has been achieved, for example, the effects of being subject to 399N for 0.74 seconds. For very young or infirm people, the effect of residual risk could in fact be significant and, hence, the residual risk assessment shall attempt to reduce the degree of harm possible. Where high risk exists (e.g. at a school), non-contact solutions, even lower force than the standard allows or additional beams shall be given the highest priority.

Vehicle related hazards shall be considered and provided for at this stage as the state-of-the-art is primarily concerned with the safety of people, not vehicles.

Residual risks can be controlled by applying suitable measures, e.g. one or a combination of the following, shown in order of merit for the protection of vulnerable users:

- | | | |
|----------------------------|------------------------|-----------------------|
| 1) non-contact | 7) activation devices | 13) traffic lights |
| 2) very low force | 8) pedestrian railings | 14) vehicle detectors |
| 3) additional photo beams | 9) signage | 15) traffic calming |
| 4) warning lamps | 10) zone lighting | 16) user warnings |
| 5) LED warning strips | 11) hazard tape | 17) user instructions |
| 6) audible warning devices | 12) ground markings | 18) user training |

Selection of appropriate residual controls shall be arrived at based on a local risk assessment. Unlike the main body of hazards dealt with by the state-of-the-art, where the focus is on the potential degree of harm, the control of residual risks can be based on likelihood of occurrence and frequency of exposure.

The need for residual hazard controls reduces as the likelihood of contact with a residual hazard diminishes on a given site. Great care is required none the less as, in the event of an incident, the findings of the residual risk assessment will be brought into judgement to some degree at least. Written user warnings, safe use instructions and user training shall be provided and are an important aspect of residual hazard control.

The auditor shall examine the residual risk assessment and obtain a declaration signed and dated by a principal of the organisation confirming they carried out a residual risk assessment for all installation as per the requirements of Clause 3.14. The auditor shall sample records to verify the requirements of Clause 3.14 are being met.

Non Compliance: Category 1

4 SYSTEM DESIGN - COMPLIANCE & RESIDUAL RISK ASSESSMENT PROCESS

The assessment process in this section applies equally to new or extensively modified systems, reactive maintenance, planned preventative maintenance and minor modifications. Reference is made to the Machinery Directive Essential Health and Safety Requirements in this section, but the Machinery Directive Essential Health & Safety Requirements are technically only relevant, and hence need to be recorded, for new and extensively modified systems (see section 4).

The actual requirements for safety are however the same for all automated gate and barrier work and are described in section 1 which reflects and clarifies the requirements of the various applicable standards and represents the state of the art.

This risk assessment process shall be conducted for the design of a new system, installation of a complete system supplied by a 3rd party, upon modification of an existing system and prior to taking on any reactive or planned maintenance of a system for the first time.

The risk assessment process shall be documented and split into seven distinct steps with each step properly documented, described below in 4.1 to 4.7 and recorded as per 4.8.

4.1 Describe the System

Describe the system, the nature of users, the environment, the activation methods and the expected duty cycle, etc.

The auditor shall examine the system design meets the requirements of Clause 4.1.

Non Compliance: Category 2

4.2 Identify and make a numbered list of all possible hazards associated with the system, including those arising from foreseeable misuse

Make a list of all hazards associated with the system: structural, electrical, control or safety system, moving parts, wear and tear, etc. This part is simply a list of all the things that could present a hazard in normal use and under foreseeable misuse. This section shall not be confused with describing specific 'faults' with a given system; it is a list of potential hazards that shall be controlled.

The auditor shall examine the system design meets the requirements of Clause 4.2.

Non Compliance: Category 2

4.3 Resolve as many hazards as possible by application of, or checking the existing, safe design principles

Provide (or propose for existing systems) measures to resolve or reduce as many of the hazards listed in step 2 as possible by improving the design to eliminate or reduce the hazard. These will include structural integrity, safe distances and clearances, guards & enclosures, electrical safety, and control/safety system integrity.

The auditor must be satisfied that all measures to resolve or reduce hazards are taken during the design process..

Non Compliance: Category 2

4.4 Apply, or check the existing, state of the art control measures for the remaining hazards

Provide (or propose for existing systems) permitted measures to control all remaining hazards: hold-to-run, inherent force limitation, safe edge force limitation, non-contact presence detection.

In all cases, the state-of-the-art standards represent the absolute minimum acceptable level of safety needed for legal compliance.

The auditor must be satisfied that state of the art control measures have been checked and applied, where appropriate. The auditor shall sample records to verify the requirements of Clause 4.4 are being met.

Non Compliance: Category 2

4.5 Identify the remaining minor residual hazards

Identify and list the residual hazards (hazards that remain when the state-of-the-art is achieved). Consider the risk to vulnerable users, e.g. high numbers of children, persons with mobility, sight, hearing, learning limitations. Protection of vehicles shall also be considered at this stage; the state-of-the-art is mainly focused on the safety of people.

The auditor must be satisfied that remaining minor residual hazards have been identified and listed. The auditor shall sample records to verify the requirements of Clause 4.5 are being met.

Non Compliance: Category 2

4.6 Design user instructions and warnings

Provide (or propose for existing systems) residual hazard control measures based on the likelihood of occurrence, frequency of occurrence and user vulnerability. If necessary, consider reducing some hazards further, e.g. by proposing even lower force, additional photo beams, non-contact technology or re-design. Residual hazard controls include things like warning lights, markings, signage and other pedestrian or traffic control systems.

The auditor shall inspect the system design proposal and confirm that it satisfies the requirements of Clause 4.6.

Non Compliance: Category 2

4.7 Design planned preventative maintenance instructions

Provide (or assess the existing) operation, maintenance manual (O&M).

The user section shall identify and explain the residual hazards. Safe use instructions shall explain how to use the system and specify any user training necessary. There shall also be a section that explains how the safety systems function, how to identify a fault and what to do/not do, including how to isolate the system and use it in manual.

The maintenance section shall explain the steps necessary to keep the system in a safe condition. For example, the inspections, cleaning, lubrication, adjustment, routine parts replacements, and safety testing necessary. The manual shall also describe the frequency,

skills, qualification and experience necessary for each task.

The auditor must be satisfied that the operation and maintenance manual is set out as specified in Clause 4.7 and have issued to the clients.

Non Compliance: Category 2


4.8 *Record the process*

Record all seven steps and retain them for inclusion on the relevant technical or maintenance file. Annex A sets out one possible way of executing and recording this process. If this system is not used, any alternative method shall achieve the same level of safety and clearly document all seven steps.

The auditor must inspect the processing records and ensure all requirements of Clause 4.8 are met.

Non Compliance: Category 2

Compliance Assessment Process Flow Diagram



5 COMMISSIONING

The commissioning process is a series of inspections, checks and tests conducted to ensure a system is functioning correctly and safely prior to placing into service or returning to service following maintenance, repair or modification. The actual steps necessary will be dictated by the exact nature of the system in question but shall in any case ensure it is safe before leaving in service. The commissioning process is a combination of following manufacturer's installation instructions and checks to ensure that all hazards present have been identified, prevented, controlled or reduced correctly and that nothing has been missed.

The process shall cover at the very least the following areas, but also assess every possible critical element based on the site, environment, design, user profile and client requirement.

5.1 Structural Integrity

- Foundations, structures, supports, welding and fixings are secure and resilient
- Guides, tracks, rollers and hinges are secure and resilient
- Travel stops secure, properly aligned and resilient
- Safety distances to prevent crush hazards correct (measure)
- Enclosures and fencing is secure and has the correct safety clearance/aperture size

5.2 Electrical Safety

- Supply is tested or has been certified by a Safe Electric registered electrical contractor
- Earth connections present and continuity to earth is tested
- Isolation is functional and securable in the off position where required
- Cabling is secure and protected mechanically
- Wire terminations correct and secure
- All cable entries are sealed
- Enclosures are sealed and secured by key or tool
- Dangerous voltage labels in place
- Polarity, continuity, insulation, earth fault loop, RCD function etc. are tested
- Safety device wiring achieves category 2 or 3 as installed

5.3 Functional Tests and Settings

- Guides, rollers and hinges operate smoothly and maintain the correct level
- Limit switches are properly set
- Operating logic correct for safety in use
- Safety device function and system response correct
- Photo beam function and response correct
- Wicket gate switches operate the stop function
- Loop detectors operate the correct command
- Intercoms, keypads, key switches, buttons, transmitters etc. operate the correct command
- Overall, that the system operates as designed and as required by the client

5.4 Performance Tests

- Hold-to-run overtravel (measure)
- Light grid or laser scanner etc. performance (test piece)
- Force limitation(force test)

5.5 Warning Devices, Signage and Markings as per Risk Assessment

- Warning lamps function and are visible
- Audible warning devices function correctly
- Road markings in place and visible
- Warning signs in place, visible and comprehensible
- Pedestrian railings in place and secure
- Pedestrian routes marked and visible

5.6 Risk Assessment

- All hazards identified and recorded
- All hazards correctly controlled
- Residual hazards correctly identified and recorded
- User warnings identified and residual hazards explained
- Safe use instructions reflect the residual hazards
- Maintenance instructions adequate

5.7 User Information

- User training completed
- User warnings provided and explained
- User instructions provided and explained
- Maintenance instructions provided and explained
- Declaration of Conformity provided (new systems)
- Certificate of compliance provided (existing systems)
- CE label fitted, visible and contains the correct information
- Commissioning completed and signed off
- Site left clean, tidy and all waste material properly disposed of

The auditor shall inspect the commissioning results for the system and confirm that the requirements of Section 5 are met. The auditor shall also inspect the paperwork and records for the installs at site visits to verify compliance with Section 5.

Non Compliance: Category 1

6. LEGAL COMPLIANCE

6.1. New and Extensively Modified Systems

6.1.1 Harmonised European Standard

A Harmonised standard is a European standard (EN) which is recognised by the European Commission as conferring a presumption of conformity with legislation on a product complying with the

standard. There are two standards currently harmonised with the Machinery Directive covering systems within the scope of this requirements document:

- EN12453:2017+A1:2021, Industrial, commercial and garage doors and gates
- EN12978, Sensitive devices for gates, doors and barriers

6.1.2 Machinery Directive

Compliance with the Machinery Directive (currently 2006/42/EC) is mandatory for the organisation who manufactures or brings an automated gate or barrier into service for the first time due to the European Communities (Machinery) Regulations 2008 in the Republic of Ireland

This will mean achieving or exceeding the level of safety prescribed in the current EU Harmonised Standard EN12453:2017+A1:2021

A new or extensively modified automated system shall conform to the Essential Health and Safety Requirements of the directive, taking into account the current “state of the art” (recital 14). This will mean achieving or exceeding the level of safety prescribed in current product specific standards (**EN 12453**). The directive is written such that the state of the art can change as standards improve without the need for revision of the directive itself.

The organisation responsible for conformity is whoever first creates the system within the European Economic Area or who first imports it into the European Economic Area (EEA).

The following activities create a responsibility for legal compliance:

- a) Manufacturing a complete automated gate or barrier within the EEA
- b) Adding an electric operator to an existing manually-operated gate
- c) Modify a complete system prior to or during installation in a way not permitted in the manufacturer’s instructions
- d) Make an extensive modification to an existing automated system that alters the way it operates
e.g.:
 - Changing from sliding to swing operation
 - Changing from ram operation to an underground operator system
 - Altering the opening width such that new leaves, supports or foundations are created
- e) Assembling components from more than one manufacturer to make a complete gate or barrier, either on site or in your own workshop, e.g.:
 - Fabricate a gate and install an operator from a 3rd party supplier
 - Install a gate from one manufacturer with an operator from another
 - Buy a collection of components from a supplier not certified by them as a complete system
 - Buy components from multiple sources which you assemble

6.1.3 Risk Assessment

A risk assessment shall be conducted that identifies and lists all potential hazards present and identifies which of the Essential Health and Safety Requirements are applicable:

- a) The nature of the system and its intended use shall be assessed
- b) Wherever possible, the elimination of as many of the identified hazards as possible shall be achieved by making design modifications to eliminate or reduce the danger
- c) Any hazard that cannot be eliminated or adequately reduced by design changes shall be reduced with a measure that achieves the current state of the art
- d) Signage, warning devices etc. and safe use instructions shall be designed to address any residual hazards.
- e) Minor residual hazards shall then be listed; hazards that can be eliminated or controlled by state of the art means cannot be declared and retained as residual hazards
- f) A set of user warnings and safe use instructions shall be created and supplied
- g) Detailed maintenance instructions shall be created and supplied

6.1.4 Partly Completed Machine

The machinery directive defines a partly complete machine (PCM) as:

“An assembly which is almost machinery, but which cannot itself perform a specific application. A drive system is partly completed machinery. Partly completed machinery is only intended to be incorporated into or assembled with other machinery or other partly completed machinery or equipment, thereby forming machinery.”

The manufacturer of partly complete machinery shall supply it with:

- a) A Declaration of Incorporation under the Machinery Directive
- b) Installation instructions for the PCM
- c) Maintenance instructions for the PCM

The PCM shall be in full compliance with and be CE marked under all applicable directives except the Machinery Directive; components in this category include electric operator and control panel combinations.

It is not permissible to supply a complete machine minus safety devices under a Declaration of Incorporation to avoid full compliance; such a machine would in fact be a complete machine without adequate safety.

6.1.5 Safety Device

The directive defines a safety device as:

“A component which serves to fulfil a safety function, which is independently placed on the market, the failure and/or malfunction of which endangers the safety of persons, and which is not necessary in order for the machinery to function, or for which normal components may be substituted in order for the machinery to function.”

The manufacturer of a safety device shall CE mark the device under the Machinery Directive and ensure that it is in full conformity with the applicable Essential Health and Safety

Requirements. It shall be supplied with a Declaration of Conformity under the directive and also be in full conformity with all other applicable directives e.g. Electromagnetic Compatibility and Radio Equipment Directives, components in this category are:

- Safe edge and any associated control device
- Light grid, laser scanner etc. and any associated control device.

As sensitive devices are listed in Annex iv of the directive, they shall either be manufactured in full conformity with the relevant harmonised standard (EN 12978) or be subject to type testing by a test laboratory notified by the European Commission to test safety devices under the Machinery Directive.

6.1.6 Maintenance Instructions

Detailed planned preventative maintenance instructions shall be drawn up by the assembler or installer of the completed system and supplied to the client, the instructions shall accurately describe the:

- Inspections
- Cleaning
- Lubrication
- Adjustment
- Replacements
- Testing
- Required frequency of maintenance

The maintenance instructions shall specify the required frequency of maintenance and the qualifications, skills and experience needed to execute the required maintenance tasks.

6.1.7 Safe Use Instructions

Instructions that identify and explain the residual hazards and how to safely use the system shall be drawn up and supplied to the client. They shall include electrical isolation, manual use, what to do in the event of a fault or damage and how to change batteries etc.

6.1.8 Declaration of Conformity (see Annex D)

The completed system shall be supplied with a Declaration of Conformity that declares conformity with the Machinery Directive, and all other relevant directives, see Annex D.

6.1.9 CE Mark

The system shall bear a CE plate that includes:

- Manufacturer or assembler name and address
- Product designation or serial number
- 2006/42/EC
- The year of manufacture

Mounted visibly and indelibly on the system see Annex D.

6.1.10 Technical File

The organisation responsible for compliance of a new or extensively modified automated system shall compile a technical file and retain it unchanged for at least 10 years after installation, to evidence the entire compliance process. The file shall be assembled and provided on request from relevant authorities. There is no requirement to share the technical file with the client. Technical files may be held with references to sites and or products and not clients in order to avoid possible conflict with data protection legislation.

The technical file shall contain at least:

- a) Technical drawings and specifications for the structure, foundations and safety critical elements such as hinges, guides, stops and fixings
- b) Calculations for loadings
- c) Detailed instructions for installation and commissioning that include any testing required
- d) The risk assessment
- e) The list of residual hazards
- f) A list of standards or parts of standards that are being relied on as evidence or part evidence of compliance
- g) Test reports from 3rd parties (where used)
- h) A copy of the Declaration of Incorporation for any partly complete machine components used
- i) A copy of the Declaration of Conformity for any safety devices used
- j) Force test report (where force limitation is used)
- k) Light grid or laser scanner etc. test report (where presence detection is used)
- l) Electrical test certificates and reports
- m) A copy of the installation manuals for all components used
- n) A copy of the user warnings and safe use instructions
- o) A copy of the planned preventative maintenance instructions
- p) The Declaration of Conformity

Companies involved in repeat use of components (e.g. PCMs and safety devices) shall operate and maintain a production control system; the system need not be independently certified (e.g. to ISO 9001) but shall be comprehensive, documented and maintained to ensure that compliance and documentation keeps pace with any supplied product changes. See Annex G.

6.1.11 Obligations

Where a system is installed by a person engaged in a trade, business or other undertaking (whether for profit or not), then that person will have duties under the Safety, Health and Welfare at Work Act 2005 to ensure the resulting system is safe.

The Safety, Health and Welfare at Work (General Applications) Regulations 2007 also require that electrical systems are installed to prevent electric shock and fire due to electrical faults. The regulations also dictate that electrical work is only conducted by persons who possess the knowledge or experience, or are working under such degree of supervision as may be appropriate, to prevent harm. Live working shall be avoided wherever possible.

In appropriate cases, a charge of reckless endangerment under the Non-Fatal Offences Against the Person Act 1997 may be considered.

The organisation must sign a declaration confirming they meet the requirements of Clause 6.1. The auditor shall sample records to verify the requirements of Clause 6.1 are being met.

Non Compliance: Category 1

6.2 Existing Systems – Repair, Maintenance and Modification

6.2.1 The Management of the Maintenance Process

There will be some variance about just how unsafe a given system may be. However, where children or untrained persons are potentially affected, the emphasis of the risk assessment shall be on degree of harm rather than likelihood of occurrence; in many cases, it is foreseeable that children could play on or around these systems or that untrained persons might encounter them. In making a determination an assessment shall result in one of two outcomes, that the system is either safe or not safe in accordance with the relevant standard or code.

Despite this, it is possible to discriminate to some degree and not all hazards will necessarily result in a system needing to be taken out of service:

- Where a hazard is classified as “safety critical”, the system shall not be returned to service by a maintenance contractor or, for that matter, by a system owner.
- Where a hazard is classified as “requiring improvement”, the system could possibly be left in service at the discretion of the maintenance contractor and/or the system owner.

In either case, a system owner shall be fully informed, and an unsafe system notice (see Annex E) issued. Where a hazard has been classified “requiring attention” and the system is left in service, the system owner remains potentially liable to criminal prosecution or civil legal action in the event of a near miss or injury incident and hence shall be given the opportunity to take the system out of service.

Organisations shall observe the following process to manage maintenance, repair and modification works.

6.2.1.1 Step 1 – Inform the Client

Before going to site, the maintenance contractor shall explain to the system owner that, as a duty of care to themselves, the system shall be taken out of service for initial electrical and

structural safety checks prior to the actual work or assessment process and, that if during maintenance or assessment work, the system proves to have safety critical defects, it will not be put back into service by the maintenance contractor.

6.2.1.2 Step 2 – Assess the Work

Once on site, the maintenance contractor shall assess the system for safety before starting work, in so far as is possible in its current condition. The maintenance contractor shall also assess the extent of work requested to be done by the system owner in terms of its likely impact on the safety of the system.

If assessment in safety is not possible due to lack of access, a System Safety Unknown (see Annex F) notice shall be issued.

If step 2 reveals that the system will be safe on completion of the proposed work, then the maintenance contractor can continue with the contracted work. If it subsequently becomes obvious during the work that the system will have safety critical defects on completion, the maintenance contractor shall not put the system back into service.

If step 2 reveals that the proposed work will not result in a safe system:

- a) The maintenance contractor shall explain all the exposed hazards to the system owner, verbally and, as soon as possible, in writing.
- b) The maintenance contractor shall also explain to the system owner what additional work (if any) might be necessary to properly diagnose the hazards; it may prove necessary to replace or adjust drive units, control boards, hinges or rolling gear etc. or work to gain access before a complete assessment is possible.

The maintenance contractor shall inform the system owner in writing of the measures that will be necessary to make the system safe.

6.2.1.3 Step 3 – Complete the Work

The maintenance contractor shall then request clearance from the system owner to complete both the contracted work and the required safety upgrade work.

If the system owner requires that the maintenance contractor completes only the contracted maintenance work the maintenance contractor shall not put a system with “safety critical” defects back into service. The contractor may only leave a system with “requiring improvement defects” in service with written permission from the system owner.

The maintenance contractor shall explain to the system owner how service can be restored (e.g. explain where the switch is or how it has been secured against collapse). In this case, it would be reasonable for the contractor to assume that the required safety upgrade work is intended to be undertaken later. The contractor shall also inform the system owner in writing (using the unsafe system notice) that there could be legal consequences for them in the event of an incident involving the system if it is returned to service in its current state.

6.2.1.4 Step 4 – Subsequent Visits

If, on a subsequent visit, the maintenance contractor finds the system is still in service in an

unsafe condition, the process shall be repeated and the system owner re-informed in writing of the potential hazards and of the potential consequences present, using the unsafe system notice. The maintenance contractor shall not be the person who puts the system back into service with safety critical defects at any stage.

6.2.1.5 Mitigating Action

Although a maintenance contractor shall never put a system with safety critical defects back into service, in many cases, a system could revert to manual use or be controlled in hold-to-run in order to maintain security at the site. This may not be undertaken where the problem is potential structural failure.

6.2.1.6 Conclusion of the Process

When informing system owners about defects affecting a system, it is important that the information outlining the defects is not confused with a quote to improve it. Accordingly, two separate documents shall be provided. The unsafe system notice shall not be ambiguous in any way. This requirements document requires the use of specific document templates to cover the informing of safety element of the process (see Annex E & F).

If a maintenance contractor continues to arrive at a site repeatedly to find that the system is still in use with safety critical defects and if, at the third visit to the site, the system owner is still resisting safety improvements, then the maintenance contractor shall request in writing a formal meeting with the system owner to discuss their ongoing intentions for safety of the system and to explore the possibility of staged improvements or other hazard mitigation strategies.

6.2.1.7 Maintenance File

The maintenance file is a record of completed maintenance and alterations to a system throughout its life. Where a maintenance file is located in the same place as a technical file care shall be taken to avoid any confusion between the two records.

The maintenance file shall include the following:

- A copy of the maintenance contract or service agreement
- A copy of the current Planned Preventative Maintenance instructions (where PPM is contracted)
- The risk assessment for initial take-over of maintenance or reactive first visit
- The risk assessment for any alteration
- The maintenance log (or a copy of it where it is retained by the system owner)
- Declarations of Conformity or Incorporation for safety device or partly complete machine replacements
- A copy of installation manuals for parts replacements (where they differ from the original)
- A copy of updated user instructions issued as a result of alterations
- A copy of unsafe system notices issued
- A copy of the certificate of compliance
- Copies of any other relevant communication with the client

6.2.1.8 Maintenance Frequency and Content

Maintenance frequency and content shall in the first instance be specified by the manufacturer or assembler of the complete system. In the absence of a specified frequency and content or if the specified schedule of maintenance proves inadequate, the maintenance contractor shall design a maintenance schedule that is judged suitable to keep the system in a safe condition. Where the system owner disputes or refuses a revised schedule, this shall be treated as a “requires improvement” hazard and notified to the system owner in the manner outlined in this section.

Force limitation, light grids and laser scanners etc. shall be performance tested at least annually but need not be tested at every maintenance visit (providing that function is checked) throughout the year unless changes are made that might alter performance e.g.:

- When safe edges are replaced with a different type or size
- When a control panel that has torque adjustment is replaced
- When a drive unit or optical device is replaced

The organisation must sign a declaration confirming they meet the requirements of Clause 6.2. The auditor shall sample records to verify the requirements of Clause 6.2 are being met.

Non Compliance: Category 1

ANNEX A - Automated Gate or Barrier Compliance and Residual Risk Assessment (Informative)

Company name:

Company address:

Job reference:

Site address:

Site & system description

- ☐ New ☐ Repair ☐ Planned maintenance ☐ Modification
☐ Swing ☐ Sliding ☐ Folding ☐ Barrier

Other:

Number of leaves:

Leaf 1 width:

Leaf 2 width:

Material:

Height:

Weight:

Percentage infill:

Expected operations per hour:

and per 24-hour period:

Terrain:

- ☐ Paved ☐ Unmade/gravel ☐ Sloping ☐ Kerb crossing ☐ Crowned road

Weather conditions:

What weather conditions will the system be exposed to?

- ☐ Inside location ☐ Outside location ☐ Sheltered ☐ Exposed

Estimated maximum wind gust speed:

Other:

Activation methods:

- ☐ Hold-to-run ☐ Free exit button ☐ Loop free exit ☐ Radio fob
☐ Keypad entry ☐ Intercom ☐ Proximity access control ☐ GSM/phone activation

Other:

Users and others who may encounter the system:

- ☐ No untrained persons present ☐ Untrained persons could be present
☐ High numbers of vulnerable persons present

Nature of vulnerable persons:

Reason/location for vulnerable persons:

Hazard list

Generic hazards present with all systems are suggested, the other more system specific hazards shall be added, some guidance is shown in brackets. Users of this template shall edit the fields as required.

Hazard description	
1	Foundations and supporting structures (derailment or collapse due to supporting masonry, post, foundation or fixing failure)
2	Leaf structure (derailment or collapse due to gate leaf or barrier arm failure)
3	Hinge, guide or rolling gear (derailment or collapse due to hinge, guide wheel, cantilever carriage failure)
4	Travel stop (derailment or collapse due to the absence or failure of physical travel stops in manual or powered use)
5	Wind load (derailment or collapse due to wind load)
6	Electrical faults (earthing, cable and wiring faults etc)
7	Control system faults causing loss of safety (safe edge, light grid, laser scanner, wicket gate switch, limit switch control system faults)
8	Crush at the leading edge (gates and barriers)
9	Impact in the swept area (gates)
10	
11	
12	
13	
14	
15	
16	

Hazard controls

Use the hazard numbers from the hazard list and describe how the hazard has been eliminated, reduced or controlled by state-of-the-art means, giving priority where possible to safe design, edit as required.

Hazard control measure applied/recommended (<i>delete as applicable</i>)	
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	
17	

Residual risk description		Residual risk control measures applied/proposed
1	<i>The system will become unsafe if not correctly maintained.</i>	<i>Provide suitable planned maintenance instructions.</i>
2	<i>Users may not be aware of residual hazards and may not know how to use the system safely.</i>	<i>Provide suitable user warnings and instructions.</i>
3		
4		
5		
6		
7		
8		
9		
10		

☐ Operation and maintenance instructions suitable

Declaration

Completed by:

Date:

Signature:

ANNEX B - Explanations of Essential Health and Safety Requirements (Informative)

1. Foreseeable misuse:

Shall be considered and provided for in the risk assessment.

1.1 Principles of safety integration:

The system shall be designed in the following order:

- a) Safe design used wherever possible to eliminate hazards
- b) Safety systems/devices shall be applied for hazards that cannot be designed out
- c) Warnings shall be provided for minor residual hazards

1.2 Materials & products:

All materials shall be suitable for use and environment, oils and other hazardous substances shall be properly contained.

1.3 Design of machinery to facilitate handling:

Manufacturers of complete systems shall provide a lifting plan for their clients.

1.4 Safety & reliability of control systems:

A Declaration of Incorporation shall be present from the control system manufacturer and the relevant installation manual followed. All cabling shall be protected against damage, voltage bands separated, cable size appropriate for current and volts drop, IP ratings and cabling appropriate for environment.

1.5 Control devices:

Shall be safely placed and activate a safe response.

1.6 Starting:

Not possible when a safety device is activated where that would result in dangerous movement.

1.7 Stopping:

There shall be no automatic re-start after stop command, stop shall override all other commands. Emergency stop is not normally required on fully automatic systems because activation of stop by an untrained person can cause trapping where the existing safety system would have provided adequate safety (stop and reverse).

1.8 Failure of power supply:

Loss of power shall not present danger to users, e.g. provision of manual release, battery backup or non-locking drives. Use of the system in manual shall be safe and the system shall be safe if power is restored unexpectedly.

1.9 Stability of foundations:

Foundations, supporting structures, fixings, leaves, guides, rollers, stops, hinges and foundations shall be designed to withstand 2 x the actual load without permanent distortion.

1.10 Risks of break up during operation:

Supporting structures, fixings, leaves, guides, rollers, stops, hinges and foundations shall be designed to withstand 3.5 x actual loading without failure. No single component failure can be allowed to cause a dangerous situation.

1.11 Risks due to surfaces, edges or angles:

All sharp edges and hooking hazards shall be removed or protected.

1.12 Risks related to combined machinery:

Control system integrity shall be maintained when combining systems, e.g. bollards and gate systems from differing manufacturers. When this is done by an installation contractor, they have become the modifier of a control system and shall ensure compliance with EH&SRs 1.2.1.

1.13 Risks related to variations in operating conditions:

The expected wind load shall not compromise safety.

1.14 Risks related to moving parts:

All moving parts hazards shall be identified in the risk assessment.

1.15 Choice of protection against risks arising from moving parts:

Hazards identified in 1.3.7 shall be controlled in line with this requirements document.

1.16 Risks of uncontrolled movements:

No single component failure can be allowed to cause dangerous movement e.g. sliding gate on a slope.

1.17 General requirements of guards:

Mesh size and horizontal clearances shall be appropriate, securely fixed and made anti climb.

1.18 Special requirements for fixed guards:

Only removable by key or tool, fixings shall be retained on the guard when it is removable for maintenance.

1.19 Special requirements for protective devices:

Sensitive devices shall only fail to safe, by good wiring practice and using devices in conformity with EN 12978 that achieve category 2/3 as installed.

1.20 Electricity supply:

The supply shall be provided, tested and certified to IS 10101. All cabling wiring and earthing shall be provided and tested to the state of the art e.g. EN 60204-1.

1.21 Errors of installation:

Instruction manuals shall be followed by competent, trained, skilled fitters. All work shall be inspected and tested on completion.

1.22 Risk of being trapped:

Manual release shall be provided as appropriate.

1.23 Risk of slipping, tripping or falling:

Shall be identified and controlled, residual hazards shall be highlighted and explained in the user warnings.

1.24 Machinery maintenance:

Detailed maintenance instructions shall be specified in the planned preventative maintenance instructions, including the required maintenance frequency.

1.24 Access to operation position & servicing points:

Access for maintenance in safety shall be provided.

1.25 Isolation of energy sources:

An electrical isolator shall be provided within sight of the system or made lockable on the off position. Isolators shall be “all pole” design switching line and neutral conductors.

1.27 Information and warnings:

Warning signs and ground markings shall be provided where identified in the risk assessment.

1.28 Warning devices:

Shall be provided where identified in the risk assessment, e.g. flashing lights, traffic lights and sounders etc.

1.29 Warning of residual risks:

Shall be explained in the user instructions and warnings.

1.30 Marking of machinery:

The system shall be marked visibly, legibly and indelibly with the following minimum particulars:

- a) Business name and full address of the manufacturer
- b) CE mark and 2006/42/EC
- c) Serial number
- d) Year of manufacture/installation
- e) Electrical hazard labels where required.

1.31 Instructions:

User instructions and warnings shall be carefully compiled and passed to the client along with the required user training and demonstration.

ANNEX C - Certificate of Compliance (Normative)

Job reference:

Site address:

Postcode:

Reason for issue: ☐ Maintenance

☐ Repair

☐ Modification

Structural integrity

- ☐ Foundations, supports, welding and fixings are provided secure and resilient
- ☐ Guides, tracks, rollers and hinges are secure, aligned and resilient
- ☐ Travel stops secure, properly aligned and resilient
- ☐ Resistance to wind load correct for environment
- ☐ Safety distances to prevent crush hazards correct
- ☐ Fence enclosures secure and have the correct safety clearances

Electrical safety

- ☐ Earth connections correct and secure
- ☐ Wire terminations correct and secure
- ☐ Enclosures and cable entries sealed
- ☐ Supply conforms to ET 101
- ☐ Isolation is functional
- ☐ Safety devices achieve category 2 or 3 as installed
- ☐ Cabling is secure and protected mechanically
- ☐ Cable sizes and specifications correct
- ☐ Dangerous voltage labels in place
- ☐ Conductive metalwork continuity to earth is tested
- ☐ Electrical tests completed

Functional tests and settings

- ☐ Limit switch/system properly set
- ☐ Safety device function and response correct
- ☐ Wicket gate/door switches operate the stop function
- ☐ Intercoms, keypads, key switches, buttons, transmitters etc. operate the correct command
- ☐ The system operates as designed
- ☐ Operating logic correct for safety in use
- ☐ Photo beam function and response correct
- ☐ Loop detectors operate the correct command

Safety performance tests

- ☐ Hold-to-run overtravel measured
- ☐ Non-contact presence detection systems tested
- ☐ Force test results assessed and indicate safe force at all hazards protected by force limitation
- ☐ Force limitation tested

Warning devices, signage and markings

- ☐ Warning devices, signage and markings provided as per the residual risk assessment
- ☐ Warning lamps function correctly
- ☐ Audible warning devices function correctly
- ☐ Road markings in place and visible
- ☐ Warning signs in place, visible and comprehensible
- ☐ Pedestrian barriers in place and secure
- ☐ Pedestrian routes marked and visible

Compliance assessment

- ☐ All hazards identified
- ☐ All hazards correctly controlled
- ☐ Residual risks correctly identified
- ☐ User warnings explain residual risks
- ☐ Safe use instructions reflect the residual risks

Maintenance

- ☐ Maintenance instructions adequate
- ☐ Maintenance interval adequate
- ☐ Maintenance tasks completed
- Maintenance interval months

User information

- ☐ User training completed
- ☐ User warnings provided and explained
- ☐ User instructions provided and explained
- ☐ Maintenance instructions provided and explained
- ☐ Maintenance log provided (new systems) and updated (existing systems)

On the date indicated this system is safe and at that time satisfied the legal obligations of both the owner and the maintaining company.

Completed by: Signature: Date:

Position:

ANNEX D - Declaration of Conformity & CE Mark (Informative)

Organisation:	Address:
Declaration of Conformity Description & unique identification number: The organisation above declares under its own authority that the system above is fully compliant with: ☐ 2006/42/EC - Machinery Directive The organisation additionally declares under its own authority that the system is in full compliance with the following directives:	

Organisation:	Address:
 2006/42/EC	Year:
	Description:
	Unique identification no:

ANNEX E - Unsafe System Notice (Normative)

Dear: Job reference number:

System type:

Reference:

.....

Location:

..... Date:

In our opinion, the above system is currently not safe for operation.

Continued use of this system may result in damage to property or injury to users or members of the public generally. Overleaf is a list of faults we consider necessary to be rectified before the system can be regarded as safe in operation. We also attach an estimate of the cost of this work if undertaken by us.

You are reminded that, as the system owner, you have a legal duty of care to users and to visitors to the premises (including trespassers). If the system is not maintained in a safe condition, any party whose property is damaged, or who is injured by the system is likely to be able to sue for damages. If you have insurance covering such risks, your insurance contract is likely to oblige you to disclose material facts to your insurer such as, in this case, the fact that the system is not considered safe.

Depending on location and use, there may well also be responsibilities for the system owner under health and safety law. Failure to meet duties imposed by health and safety legislation could result in criminal proceedings.

Due to our own responsibilities under criminal law as a system maintainer, we are unable to leave a system with "safety critical" defects in service. Where a system has lesser safety issues that are rated as "requiring improvement", we may leave the system in service at your discretion. Where a system with defects requiring improvement is left in service, there may well still be legal liabilities for the system owner in the event of an incident resulting in damage to property or injury. We strongly advise that all safety related defects are resolved with immediate effect to protect the interests of both the system owner and users of the system.

The system has been left:
(e.g. "switched off", "set to hold to run control", "as found", "secured against collapse" etc.)

Yours faithfully: Signature:

Exposed system hazards: SC = Safety Critical / RI = Requiring Improvement

1. SC/RI:
2. SC/RI:
3. SC/RI:
4. SC/RI:
5. SC/RI:

ANNEX F - System Safety Unknown Notice (Normative)

Dear: **Job reference number:** **System type:**

..... **Reference:**

..... **Location:**

..... **Date:**

We are unable to gain access to some safety critical elements of your system.

As part of routine maintenance, repair or modification works we need to gain access to the safety critical areas of your system for inspections, adjustments, cleaning, lubrication or testing. Without this access we are unable to ascertain the safety of your system and hence are unable to determine whether or not it is safe to use.

Continued use of the system could result in damage to property or injury to users or members of the public generally. You are reminded that, as the system owner, you have a legal duty of care to users and to visitors to the premises (including trespassers).

If the system is not maintained in a safe condition, any party whose property is damaged, or who is injured by the system is likely to be able to sue for damages. If you have insurance covering such risks, your insurance contract is likely to oblige you to disclose material facts to your insurer such as, in this case, the fact that safety of the system could not be ascertained.

Depending on location and use, there may well also be responsibilities for the system owner under health and safety law. Failure to meet duties imposed by health and safety legislation could result in criminal proceedings.

Due to our own responsibilities under criminal law as a system maintainer, we are unable to leave a system in service where we cannot ascertain its safety. If a system is left in service where the safety of it cannot be ascertained, there may well be legal liabilities for the system owner in the event of an incident resulting in damage to property or injury. We strongly advise that you arrange for structural alterations that will make routine access for maintenance of your system possible with immediate effect to protect the interests of both the system owner and users of the system.

We would be happy to advise what access is necessary.

The system has been left: (e.g. "switched off", "set to hold to run control", "as found", "secured against collapse" etc.)

Yours faithfully: **Signature:**.....

ANNEX G - Factory Production Control (FPC) Checklist (Informative)

This section highlights some of the areas for consideration when designing a Factory Production Control system as an alternative to a full ISO 9001 system. An FPC system is needed wherever manufacture of gates or traffic barriers occurs.

General

- Are written procedures/work instructions issued to the shop floor?
- Are they “controlled” so that updates can be consistently applied?
- Identify the documents relevant to the product(s) being CE marked
- Do you directly control the machinery used to manufacture the product?
- If not, and you use a sub-contractor, what controls are in place?

Personnel

- Who is the management representative in overall charge of FPC and with responsibility for ensuring that its requirements are applied?
- Are the personnel involved in production qualified and trained to operate and maintain the equipment and carry out production line duties?

Equipment

- Is maintenance of the process machinery carried out to written procedures at regular intervals?
- Are the results recorded?
- Is the inspection equipment correctly maintained and calibrated to ensure constant accuracy of tests performed during FPC?
- How is the frequency of calibration controlled?
- Are records kept?

Design

- Where relevant, are the responsibilities for the stages of the design process defined?
- Do procedures contain details of any design checks to be carried out?
- Raw materials and components
- What are the procedures/routines covering the purchase of raw materials and components?
- Do purchase orders detail specific requirements such as grade of steel

or type of glass?

- Are specifications agreed with certain suppliers?
- Are any certificates of analysis or conformity requested from suppliers?
- Are batches of raw materials or components traceable through the production process and in finished products?
- If so, how is this traceability maintained?

Production Process Control

- How is the flow of production controlled? Are job sheets or works orders raised for each batch/day/week of production?
- How is progress recorded?
- What records are generated?
- Are all production processes and procedures recorded at regular intervals?
- Who records the processes?
- Is the recording automatic?
- How is the documentation organised?
- Is product testing carried out on site?
- If not, then where?
- Check test records for recent production. Do the results match the requirements of the technical specification?

Traceability and Marking

- How are product batches traceable through the production process and in finished products?
- What records are maintained of where the finished products are shipped?
- How is production batch number traceability maintained after dispatch to assist in traceability in the event of a complaint being received?
- How long are records kept?

Non-conforming Product

- Is there a documented inspection system that allows detection of defects before delivery?
- What proportion of products is inspected?
- How are any non-conforming products identified and stored?
- What records are kept?

Corrective Action

- Does the system include action to prevent future non-conformities?
- Who is responsible for:
- Investigating the cause of non-conformities?

- Correcting non-conformities?
- Is there an adequate documented system concerning complaints received about products and is the system integrated into the FPC?
- How are customer complaints addressed?

Handling, Storage and Packaging

- Are procedures in place for storing and handling raw materials, components and products to prevent damage and deterioration?

ANNEX H – Complete new system non-compliance process

(Normative)

When an installation company sources a system from a 3rd party supplier, they shall be careful to understand what they have ordered. Have they ordered a disparate collection of parts, or a complete system? If a collection of parts was ordered, the installation company bears full responsibility for compliance. If a complete system was ordered, the importer, distributor, or manufacturer, whoever first placed it on the market, has responsibility for compliance.

Where there are residual hazards specific to the local environment, the site or the nature/vulnerability of users, the installation company shall deal with them as part of the 'as installed' compliance assessment, at the residual risk stage.

There may be occasions where an installation company has been supplied with a complete system supported by declarations and CE marking, but the system appears to have some hazards that are not protected in line with the state-of-the-art.

Where this happens, it is important to understand the various roles and responsibilities under criminal or civil law:

1. The supplier of the complete system is responsible for compliance.
2. The installation company shall follow the supplier's installation instructions.
3. The installation company has a duty to report any apparent non-compliance to the supplier, and ultimately to the client if the supplier declines to respond.
4. If the installation company makes safety improvements not authorised by the supplier, the installation company takes on responsibility for compliance and could suffer some loss of warranty cover.
5. The client has legal responsibilities if they choose to keep the system in service below the state-of-the-art.
6. There is potential for the installation company to bear legal liability when they fail to communicate any concern over the safety of a system to either the supplier or the client if they could reasonably have been expected to understand the issues at stake, e.g. they are qualified in the appropriate standards and legislation.